


**Nancy Cooley**

---

**From:** Nancy Cooley  
**Sent:** Monday, October 24, 2016 4:17 PM  
**To:** 'Kurt Eggers'  
**Subject:** RE: Idaho Power Transmission Line



Hi Kurt,

Utilities are exempt from the 100' setback.

**§9-3-10: STRUCTURE SETBACK ON HIGHWAY 75:**

*All structures along Highway 75 shall be set back a minimum of one hundred feet (100') from the edge of the right of way. Utilities and driveways are exempt. Signs within this setback are regulated in chapter 29 of this title. Fences, walls, earthen structures and landscape are regulated in chapter 21A of this title. Address markers are regulated in section 7-7-5 of this code*

Nancy

*Nancy Cooley  
Zoning Specialist  
Blaine Co. Land Use and Building Services  
208-788-5570 Ext.1147*

---

**From:** Kurt Eggers [mailto:Kurt@eggersassociates.com]  
**Sent:** Thursday, October 20, 2016 3:11 PM  
**To:** Tom Bergin <tbergin@co.blaine.id.us>; Nancy Cooley <ncooley@co.blaine.id.us>  
**Cc:** pzcounter <pzcounter@co.blaine.id.us>  
**Subject:** Idaho Power Transmission Line

I am wondering if the proposed transmission line needs to go through a review process for the Scenic Highway Overlay District?

I don't see any information relative to that in the materials.

Thanks

Regards,

**Kurt Eggers**  
**Eggers Associates P.A.**  
*landscape architecture*  
P.O. Box 953  
560 North Second  
Ketchum, ID 83340  
208-725-0988

