

Wood River to Ketchum Transmission Line

- Built in 1962
- Difficult / Remote Access
- Wood poles

Outage History Since 1966:

- 6 "Sustained" Outages (>5 min)
 - 2 scheduled maintenance outages
- Average duration 2.6 hrs
 - 6 hr longest duration
- 66% have occurred since 2004
 - Increasing failure rate
- **3 Outages** to Sun Valley / Ketchum
 - Due to simultaneous outages on both lines, Midpoint and King Lines
 - Christmas 2009 outage (11 hr 40 min)
 - Two short duration outages (5 min, 10 min)

Single Line Poses Significant Risk of Long-term Outage to Sun Valley and Ketchum

