

## Kristine Hilt

---

**From:** Jeff Loomis  
**Sent:** Thursday, September 9, 2021 10:50 AM  
**To:** Kristine Hilt  
**Subject:** Hohman Bridge Replacement SAP Application - County Engineer Review

Kristine -

Based on my review of the application documents and follow-up discussions with the applicant's engineer, I believe this application satisfies the SAP criteria for evaluation with the following additional submittals or statements on record from the applicant's engineer:

- Approval of the bridge design from Fire District
- The additional bridge abutment construction specification requiring compaction of placed stream bed and stream bank material to the approval of the project engineer.
- Construction drawings specifying the project shall meet State of Idaho SAP water quality requirements, and any necessary notes indicating specific measures the contractor must implement to meet those requirements.

Please let me know if you have questions. Thank you.

JEFF LOOMIS, PE  
Blaine County Engineer