



117 East Walnut Street, Hailey, Idaho 83333

208-788-5577 Fax 208-788-5579

January 9, 2023

Samantha Stahlnecker, P.E.
Brooke Bonner



Reference: Drinkers of the Wind Preliminary Plat Review

The Wood River Fire Protection District has been asked to provide written comment regarding the above subdivision.

The preliminary plat shows four buildable lots and one un-buildable lot. Section 7-7-5 paragraph D of the Blaine County Fire Protection Ordinance requires pressurized fire hydrant systems in any new subdivisions containing five or more lots. The proposed fifth lot in this subdivision is un-buildable and shall remain un-buildable as noted in plat note 14 therefore no pressurized water system is required.

The requirements in plat note 12 cover any Fire District requirements as each lot is developed in the subdivision. Building permit plan reviews and fire inspections are required as each lot is built upon.

Please feel free to contact me if you have any additional questions

Sincerely,

A handwritten signature in black ink that appears to read "Mike Elle".

Mike Elle
Fire Marshal