



117 East Walnut Street, Hailey, Idaho 83333

208-788-5577 Fax 208-788-5579

March 4, 2022

Nancy Cooley, Blaine County Land Use and Building Services

**Reference: Request for Comment, Lemhi Drive Fire Access Requirements**

The Wood River Fire Protection District has been asked to provide written comment on the adequacy of fire apparatus access for compliance with adopted fire protection requirements. A copy of the project drawings was provided to me for this review.

The proposed buildout of Lemhi Drive appears to comply with the fire code. The grade and width of the roadway meet the intent of the Blaine County Fire Ordinance. The fire apparatus turnaround near the end of Lemhi Drive meets requirements as does the vehicle turnout located at the turn of Lemhi Drive.

Additional review by the Wood River Fire Protection District will be required as each lot submits Building Permit applications. Final approval of the Lemhi Drive project will be given after an inspection once construction has been completed.

Please feel free to contact me if you have any questions regarding this project.

Sincerely,

Mike Elle  
Fire Marshal  
[melle@wrfir.com](mailto:melle@wrfir.com)  
(208)578-6453

RECEIVED

MAR 07 2022

BLAINE COUNTY  
LAND USE & BUILDING SERVICES

B-2  
Exhibit